

Mamad Inspection

Complete before escalation and recheck monthly. Based on HFC residential protected-space guidelines.

Two-person drill: one person reads the CALL column aloud, the other responds. Alternate roles each time.
Solo: read each call aloud, then answer it yourself.

Structural Inspection

	ITEM	CHECK	
	Blast Door 	☐ Opens & closes? ☐ Handle turn? ☐ Double lock?	SMOOTHLY 90° UPWARD FUNCTIONS
	Door Seal 	☐ Rubber insulation? <i>Replace if dried, cracked, or brittle</i>	PRESENT
	Light Test 	☐ Light when sealed? <i>Light penetration = inadequate seal</i>	NONE VISIBLE
	Steel Outer Window	☐ Opens & closes?	SMOOTHLY
	Glass Inner Window	☐ Functions? <i>Double-wing: remove both wings during escalation, store outside room</i>	CORRECTLY
	Ventilation Pipes	☐ Rubber insulation? ☐ Steel cover screws?	INTACT TIGHT

Contents & Safety

	ITEM	CHECK	
	Flammable / Hazardous 	☐ Hazardous materials?	NONE
	Glass / Ceramics 	☐ Glass, ceramic, porcelain? <i>Can shatter into projectiles</i>	NONE
	Heavy Items	☐ Shelves & heavy items?	FIXED TO WALLS
	Gas Tanks	☐ Distance from walls?	3+ METRES
	Emergency Supplies	☐ Supplies?	STORED INSIDE or NEARBY
	Ceiling Fan	☐ Ceiling fan installed? <i>Prohibited in mamads</i>	NONE
	Ventilation	☐ Room ventilated? <i>Must NOT be used as kitchen, bathroom, or washroom</i>	YES

